

**§ 97.532 Monitoring system out-of-control periods.**

(a) *General provisions.* Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of part 75 of this chapter, data shall be substituted using the applicable missing data procedures in subpart D or subpart H of, or appendix D or appendix E to, part 75 of this chapter.

(b) *Audit decertification.* Whenever both an audit of a monitoring system and a review of the initial certification or recertification application reveal that any monitoring system should not have been certified or recertified because it did not meet a particular performance specification or other requirement under § 97.531 or the applicable provisions of part 75 of this chapter, both at the time of the initial certification or recertification application submission and at the time of the audit, the Administrator will issue a notice of disapproval of the certification status of such monitoring system. For the purposes of this paragraph, an audit shall be either a field audit or an audit of any information submitted to the Administrator or any State or permitting authority. By issuing the notice of disapproval, the Administrator revokes prospectively the certification status of the monitoring system. The data measured and recorded by the monitoring system shall not be considered valid quality-assured data from the date of issuance of the notification of the revoked certification status until the date and time that the owner or operator completes subsequently approved initial certification or recertification tests for the monitoring system. The owner or operator shall follow the applicable initial certification or recertification procedures in § 97.531 for each disapproved monitoring system.

**§ 97.533 Notifications concerning monitoring.**

The designated representative of a TR NO<sub>x</sub> Ozone Season unit shall submit written notice to the Administrator in accordance with § 75.61 of this chapter.

**§ 97.534 Recordkeeping and reporting.**

(a) *General provisions.* The designated representative shall comply with all recordkeeping and reporting requirements in paragraphs (b) through (e) of this section, the applicable recordkeeping and reporting requirements under § 75.73 of this chapter, and the requirements of § 97.514(a).

(b) *Monitoring plans.* The owner or operator of a TR NO<sub>x</sub> Ozone Season unit shall comply with requirements of § 75.73(c) and (e) of this chapter.

(c) *Certification applications.* The designated representative shall submit an application to the Administrator within 45 days after completing all initial certification or recertification tests required under § 97.531, including the information required under § 75.63 of this chapter.

(d) *Quarterly reports.* The designated representative shall submit quarterly reports, as follows:

(1) If the TR NO<sub>x</sub> Ozone Season unit is subject to the Acid Rain Program or a TR NO<sub>x</sub> Annual emissions limitation or if the owner or operator of such unit chooses to report on an annual basis under this subpart, the designated representative shall meet the requirements of subpart H of part 75 of this chapter (concerning monitoring of NO<sub>x</sub> mass emissions) for such unit for the entire year and shall report the NO<sub>x</sub> mass emissions data and heat input data for such unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:

(i) For a unit that commences commercial operation before July 1, 2011, the calendar quarter covering May 1, 2012 through June 30, 2012; or

(ii) For a unit that commences commercial operation on or after July 1, 2011, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under § 97.530(b), unless that quarter is the third or fourth quarter of 2011 or the first quarter of 2012, in which case reporting shall commence in the quarter covering May 1, 2012 through June 30, 2012.

(2) If the TR NO<sub>x</sub> Ozone Season unit is not subject to the Acid Rain Program or a TR NO<sub>x</sub> Annual emissions